

The following items are reported for correction during the Fall and Winter seasons. Units may choose projects, contact Ranger Eddie, and use the outdoor facilities for day or weekend stays. Some units have supplied a steak/hamburger/chicken/chilli cookout for the volunteers to celebrate their Good Turn.

The notes are designated as either:

*A-Should be checked for correction prior to camp opening and may be included on the Official Inspection form.*

*B- Items for Service Projects, Service Weekends, and Off Season repairs.*

*The page references indicate the Post Camp Inspection page .*

**Page 2: Dining Hall and Kitchen**

Dining Hall

A- Repair/replace screening on back of hall.

B- Bimetal thermometer- locate/ purchase

B- Replace light bulbs where needed

A- Repair/replace urinal

Kitchen

B-Adjust screen door closer for closer fit

A-Repair screen on dry storage window

Page 4 Camp Vehicles, Maintenance Equipment & Storage, Tools/Safety Equipment, Camp Equipment and Storage sections will be inspected by the Ranger and/or the Maintenance Committee.

**Program Sites**

Page 5 **Rifle Range – COMPLETED**

A Trash barrel needs cover - Potential wasps/yellow jackets in firing locations

**Amphitheater – OA has this area for projects**

B Request that the seats and log supports, including stairs to stage, be checked for safety

B Remove unused conduit and wire

B Repair/replace wooden fence to right of stage

B Add trail lights from amphitheater walking trail at stage to road at Lake Bob Justice

B Soil conservation work on the right and left sides of seats

B Check power available in projection/audio building

The Order of the Arrow has taken the repair of the stage/ seating wall as their Spring project.

**Page 5 Miscellaneous**

Revamp one camp site or building with adequate facilities(wheelchair access) for handicapped Scouts. The Health Lodge is currently used with limited available space.

Could one of the 4 Scout Adirondacks be used?

Could a new one be built in an accessible location?

**Latrines (Pages 6-A & 6-B)**

Choctaw/Cheyenne/Catawba/Cherokee

B Check lighting in Scout showers --bulb or reset? - **COMPLETED**

B Stabilize step into shower

B Hot water heater stack damaged?

B Propane tanks -are tank controls secured from tampering

B Replace valve on sink and on hose outlet

Navaho

B Missing toilet lid

Apache/Blackfoot

A Check circuit box (open space next to live switch) - **COMPLETED**

Adult Showers on hill (Locked - hear water leak inside)

B Water Heater area - check flashing and fascia board/water

Latrine below Adult Showers

B Check lighting

B Water valve leaking/standing water

Creek/Crow

A Breaker trips when reset

B Secure water line (urinal to shower)

B Roof - ridge shingles - leak?

Ottawa/Seneca--Based on capacity of latrines and number of campers in this area, this latrine is needed.

B Check lighting/power

A Replace junction box cover

A Repair conduit at sink light

B Check vent - rain leak

Seminole/Zuni

B Replace exterior panels at toilet area – **COMPLETED**

B P-Trap on sink busted

Murphy Showers Scout (Page 7)

B Check for correct light switch cover at entry.

B Shower head missing

B Check lighting

B Correct leak at base of toilet-wax ring?

Murphy Adult (Page 7)

A Urinal not operational

B Repair water inlet to 1 sink

A Repair water leak in hot water heater area

Page 6-A **Adirondacks**

Page 3

B Mattresses - Begin a replacement cycle on mattresses. 30 have some damage to the plastic cover.

B Potential Hazards- Dead trees/limbs

Catawba A- large dead tree – **COMPLETED**

Catawba B- tree leaning on building

B Catawba A -broken cross member - **COMPLETED**

B Cherokee A -4x4 roof support damaged.

B Iroquois B- corner support not secure

B Building roofs- consider in roof replacement schedule on Iroquois B; Keowee A; Navaho B; Keowee

A

Page 6-B **Tent Sites-**

- B Step repair or addition: Creek (2); Pequot (3); Powhatton (1); Ottawa/Seneca (1); Seminole
- B Picnic Table: Creek (repair); Seminole;
- B Fire Ring: Cheyenne; Pequot; Sioux; Ute.
- B Tree/Branch: Creek (over tent near flagpole); Pequot (dead tree) Seminole (remove downed tree trunk)
- B Other: repair/rebuild Pueblo and Zuni when camp capacity needs dictate.
- B Platforms: Check each tent site for needed repairs.

Page 7 **Buildings**

Sarah Hardin House

- B Bathroom exhaust fans - operational?
- B Adjust bottom of door for new carpet.
- B Smoke Alarms should be checked in Spring inspection. (Batteries 9V needed)
- B Paint exterior

Senior Staff Quarters

- B Exit signs
- B Add exhaust fans in bathrooms of new Staff Quarters
- B Smoke Alarms should be checked in Spring inspection. (Batteries 9V needed)

Female Staff Quarters

- A Repair floor in bathroom

Staff shower at Staff Lounge (outside entrance).

- B Repair/replace entrance boards.

**Water Supply- Storage Tanks – COMPLETED**

A Repair/replace the gate to better control access to the tanks

A Clear underbrush/limbs

A Check for exposed wiring

The lavatories and showers in the Lounge are no longer being used. This area has potential for washers and dryers for Staff, storage, or for other camp needs..

Bob Holmes

August 23, 2009